

Tremco CPG Germany GmbH
Trauring 65
83301 Traunreut
GERMANY

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

CustomerSupport@eurofins.com
www.eurofins.com/VOC-testing

VOC EMISSION TEST REPORT


Indoor Air Comfort GOLD®

31 August 2021

1 Sample Information

| | |
|------------------------|------------------|
| Sample name | FA890 anthracite |
| Batch no. | 06/21-82084001 |
| Stated production date | 23/06/2021 |
| Product type | Joint sealant |
| Sample reception | 19/07/2021 |

2 Brief Evaluation of the Results

| Regulation or protocol | Conclusion | Version of regulation or protocol |
|--------------------------|---|--|
| French VOC Regulation |  | Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A) |
| French CMR components | Pass | Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A) |
| Italian CAM Edilizia | Pass | Decree 11 October 2017 (GU n.259 del 6-11-2017) |
| ABG/AgBB | Pass | Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021) |
| Belgian Regulation | Pass | Royal decree of May 2014 (C-2014/24239) |
| EMICODE | EC 2 | April 2020 |
| Indoor Air Comfort® | Pass | Indoor Air Comfort 7.0 of May 2020 |
| Indoor Air Comfort GOLD® | Fail | Indoor Air Comfort GOLD 7.0 of May 2020 |
| Blue Angel (DE-UZ 123) | Pass | DE-UZ 123 for "Low-Emission Sealants for Interior Use", (January 2019) |
| BREEAM International | Exemplary Level | BREEAM International New Construction v2.0 (2016) |
| BREEAM® NOR | Pass | BREEAM-NOR New Construction v1.2 (2019) |

Full details based on the testing and direct comparison with limit values are available in the following pages
Regarding pass/fail decision rule please see appendix



Rasmus Verdier
Analytical Service Manager



Janne Rothmann Norup
Analytical Service Manager